

Job Name : _____
 Purchaser : _____
 Engineer : _____
 Submitted To : _____
 Submitted By : _____
 Unit Designation : Schedule No.: _____

Location : _____
 P.O. No. : _____
 Architect : _____
 Date : _____
 For : Reference Approval Construction
 Model No.: _____



Submittal Data : LS120CE

Capacities :

Cooling 11,500 Btu/h
 Outdoor Design Temp.(°F,DB/WB)
 Cooling 95/75
 SEER 13
 EER.....10

Indoor Unit :

Power Supply (V,Ph,Hz) 36V DC
 Maximum Fuse Size.....Powered by
 Minimum Ampacity.....Outdoor Unit
 Weight (lbs).....20.5
 Sound (dB(A),H/M/L Cool).....41/36/34
 Air Circulation (CFM).....330
 Dehumidification (pts/hr) 3.0

Outdoor Unit :

Power Supply (V,Ph,Hz) 115,1,60
 Maximum Fuse Size.....20
 Minimum Ampacity.....10.5
 Weight (lbs).....72.8
 Sound (dB(A), High Cool) 48

Refrigerant Piping :


Maximum Length (ft).....50
 Maximum Height Difference (ft).....25
 Liquid Side (O.D).....1/4"
 Gas Side (O.D).....1/2"

Standard Features :

- Five Year Compressor Warranty
- Two Year Functional Parts Warranty
- R-410a Refrigerant
- Triple Filter Air Purifying System
- Chaos Swing Air Circulation
- Jet Cool™
- LCD Wireless Remote Controller
- Auto Restart
- 24 Hour On/Off Timer
- Built-in Low Ambient Control down to 0°F
- Temperature Display on Indoor Unit

Note :

LSN120CE



LSU120CE

